

**ADC Planning Consultation
Response from the Historic Buildings Adviser**

Application Number	BR/73/14/L
Address	16 Aldwick Road Bognor Regis PO21 2LP
Description	Application for listed building consent to replace 9 No windows.
Case Officer	Simon Davis
Site Visit	

No Objection

Whilst double-glazing is not normally acceptable in listed buildings, it has been agreed to here due to the conditions within the building. Apparently there are issues with condensation which may well have been exacerbated by previous damp treatments to the walls.

Please condition details of windows to show exact design. Please note that double glazing should be kept to a minimum, preferably 10-12mm.

Ian Wightman
Historic Buildings Adviser

Please note: The observations and comments expressed on this sheet are the views of the consultee concerned and are in no way binding on either the Council or its senior officers when making a decision on the application. Applicants or their agents should contact the case officer before acting on these views.