

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 21 April 2022 14:39

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 1 Spencer Street Bognor Regis PO21 1AP - BR/74/22/DOC

Planning Application Reference: BR/74/22/DOC

Proposal: Approval of details reserved by condition imposed under BR/277/21/PL relating to condition 3-internal sound pressure levels.

Location: 1 Spencer Street Bognor Regis PO21 1AP

Condition 3 – Internal Sound Pressure Levels

Having reviewed the report entitled ' Discharge of Planning Condition | Site: 1 Spencer Street, Bognor Regis, PO21 1AP' (dated 29/03/2022) [produced by Acoustic Associates Sussex Ltd.], I find the report, methodology and findings to be reliable. I therefore recommend that the condition be discharged providing the development proceeds in accordance with the Acoustic Associates report, such that glazing shall achieve a minimum sound insulation performance value of $R_w + C_{tr} = 25\text{dB}$ and trickle vents to achieve a minimum sound insulation performance value of $D_{n,E,w} = 42\text{dB}$.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

