

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 12 May 2022 13:28

To: Planning.Responses <Planning.Responses@arun.gov.uk>; Obafemi Okusipe <Obafemi.Okusipe@arun.gov.uk>

Subject: 83 Aldwick Road Bognor Regis PO21 2NW - BR/79/22/PD

Planning Application Reference: BR/79/22/PD

Proposal: Prior Notification under Schedule 2, Part 3, Class M for the change of use from shop (Use Class E) to 1 No dwelling house (Use Class C3).

Location: 83 Aldwick Road Bognor Regis PO21 2NW

Dear Obafemi,

Environmental Health has no objection to the above proposal, however the following matters must be considered.

Construction – Small Developments

The development shall be carried out in accordance with the 'Arun District Council Construction Code of Practice: For small developments in Arun', available from:

<https://www.arun.gov.uk/download.cfm?doc=docm93lijm4n12193.pdf&ver=12201>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Road Noise

No development shall commence until an acoustic assessment has been undertaken to determine the impact of noise from transport related noise sources on the B2166. The assessment shall be in accordance with the 'shortened measurement method' described in the Department for Transport document 'Control of Road Traffic Noise' (CRTN) 1988. The results of the assessment and details of a scheme of mitigation measures necessary to ensure an appropriate level of aural amenity within habitable rooms and amenity in garden areas shall be submitted and approved in writing by the Local Planning Authority. All works, which form part of the approved scheme, shall be completed before any part of the development is occupied and shall thereafter be maintained in accordance with the approved details.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Commercial Noise Sources

No development shall commence until an acoustic assessment has been undertaken to determine the impact of noise from commercial related noise sources on the proposed dwellings. The results of the assessment and details of a scheme of mitigation measures necessary to ensure an appropriate level of aural amenity within habitable rooms and amenity in garden areas shall be submitted and approved in writing by the Local Planning Authority. All works, which form part of the approved scheme, shall be completed before any part of the development is occupied and shall thereafter be maintained in accordance with the approved details.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Internal Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

