



Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
BR/80/17/PL
Our Ref
PLAN-017925
Date
20/04/2017

Dear Sirs,

Proposal: 1No. detached two bed bungalow. Resubmission of BR/163/16/PL.
Site: Land East of Pumping Station, High Croft Close, Bognor Regis, PO22 8DS.
BR/80/17/PL

Thank you for your letter of 04/04/2017.

Southern Water objects to the proposed development as due to the vibration, noise and potential odour generated by sewage pumping stations, no habitable rooms should be located closer than 15 metres to the boundary of an existing pumping station site.

Yours sincerely



Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9400SW

Scale: 1:1250

Screen Print

ARUN DISTRICT COUNCIL BR/80/17/PL

WARNING: BAC pipes are constructed of Banded Asbestos Cement

WARNING: Unlabeled (H/K) materials may include Banded Asbestos Cement



Printed By: banuh

Date: 13-4-2017

Southern Water MapGuide Browser

Requested By: