

Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2018/120342/01-L01
Your ref: BR/90/18/PL
Date: 03 May 2018

Dear Sir/Madam

Demolition of two storey building & erection of three storey block of 8 no. one bedroom flats & 6 no. two bedroom flats with access from Durban Road

Formerly Westside Supplies Unit, West of 17 & 18 Durban Road, Bognor Regis, PO22 9QT

Thank you for consulting the Environment Agency on the above application.

Environment Agency Position

We have **no objection** to the proposed development as submitted, **subject to the inclusion of the following condition**, in any permission granted.

We consider that planning permission could be granted to the proposed development, as submitted, if the following planning condition is included as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would object to the application.

Condition – Implementation of Flood Risk Assessment

The development permitted by this planning permission shall only be carried out in accordance with the approved Flood Risk Assessment (FRA) (September 2016) and the following mitigation measures detailed within the FRA:

- Finished floor levels are set no lower than 2.65 metres above Ordnance Datum (AOD).

The mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the timing / phasing arrangements embodied within the scheme, or within any other period as may subsequently be agreed, in writing, by the local planning authority.

Reason

In line with section 9 of the Planning Practice Guidance of the National Planning Policy Environment Agency
Canal Walk, ROMSEY, Hampshire, SO51 7LP.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

Framework (NPPF) for Flood Risk and Coastal Change to reduce the risk of flooding to the proposed development and future occupants.

Informatives

We recommend that the owner/occupants sign up to the Environment Agency Flood Warning Service and have a flood evacuation plan.

Please note that it is not our role to assess any details on flood evacuation or emergency plans, as we do not carry out these roles during a flood. Our involvement with this development during an emergency will be limited to delivering flood warnings to occupants/users covered by our flood warning network.

In all circumstances where warning and emergency response is fundamental to managing flood risk, we advise LPAs to formally consider the emergency planning and rescue implications of new development in making their decisions.

The PPG states that LPAs should consult their emergency planning staff to ensure evacuation plans are suitable through appropriate planning conditions (PPG Ref ID: 7-057-20140306).

We therefore recommend seeking comments from your Local Authority emergency planners.

We recommend that consideration be given to use of flood mitigation measures to reduce the impact of flooding when it occurs. Flood mitigation measures include barriers on ground floor doors, windows and access points and bringing in electrical services into the building at a high level so that plugs are located above possible flood levels. More information can be found in the communities and local Government publication 'Improving the flood performance of new buildings' which can be viewed at: <http://www.communities.gov.uk/publications/planningandbuilding/improvingflood>

Should you have any further queries please do not hesitate to contact me.

Yours faithfully

Miss Suz Greenwood
Planning Advisor, Environment Agency



cc Tony Rogers Building Consultant