

**From:** Simon Davis

**Sent:** 11 May 2022 13:51

**Subject:** 65-71 Upper Bognor Road Bognor Regis PO21 1HR - BR/93/22/DOC

Dear Mr Brown,

Please see comment below from our EHO re the Electric Vehicle Charging:

*Condition 17 – Charging of Electric Vehicles*

*\*\*further information is required\*\**

*The applicant shall provide information to demonstrate the following: EVCPs must have a minimum power rating output of 7kW, be fitted with a universal socket that can charge all types of electric vehicle currently on the market and meet relevant safety and accessibility requirements.*

*It appears there is an insufficient number of EVCPs to accommodate the proposed development. The applicant shall provide 1 EVCP for each new residential dwelling with associated parking within the site boundary, and one in 5 EVCPs for non-residential associated parking spaces within the site boundary.*

Please provide the requested info by the 25<sup>th</sup> May so that I can then reconsult.

Kind Regards

**Simon J Davis MRTPI**  
Principal Planning Officer  
Directorate of Place

**T:** 01903 737874

**E:** [simon.davis@arun.gov.uk](mailto:simon.davis@arun.gov.uk)

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)

To register to receive notification of planning applications in your area please go to  
<https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to [www.arun.gov.uk/cil](http://www.arun.gov.uk/cil)

Sign up to our newsletter [here](#)

