

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 11 May 2022 13:29

To: Planning.Responses <Planning.Responses@arun.gov.uk>; Simon Davis <Simon.Davis@arun.gov.uk>

Subject: 65-71 Upper Bognor Road Bognor Regis PO21 1HR - BR/93/22/DOC

Planning Application Reference: BR/93/22/DOC

Proposal: Approval of details reserved by condition imposed under BR/252/21/PL relating to conditions 8-details of eaves, guttering, materials, window, doors and other external finishes, 10-landscape scheme, 11-boundary treatments, 14-bat and hedgehog nesting facilities and 17-charging of electric vehicles.

Location: 65-71 Upper Bognor Road Bognor Regis PO21 1HR

Dear Simon,

Condition 17 – Charging of Electric Vehicles

****further information is required****

The applicant shall provide information to demonstrate the following: EVCPs must have a minimum power rating output of 7kW, be fitted with a universal socket that can charge all types of electric vehicle currently on the market and meet relevant safety and accessibility requirements.

It appears there is an insufficient number of EVCPs to accommodate the proposed development. The applicant shall provide 1 EVCP for each new residential dwelling with associated parking within the site boundary, and one in 5 EVCPs for non-residential associated parking spaces within the site boundary.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

