

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 26 June 2017 09:34
To: Planning Scanning
Subject: FW: BR/98/17/PL - Bognor - Fish'n' Chips

From: Simon Davis
Sent: 23 June 2017 10:34
To: Planning.Responses
Subject: FW: BR/98/17/PL - Bognor - Fish'n' Chips

Application Correspondence. Copy please.

From: Nick Howard
Sent: 22 June 2017 17:42
To: Abbey Kelsey
Cc: Simon Davis
Subject: Re: BR/98/17/PL - Bognor - Fish'n' Chips

Hi Abbey,

Thank you for your email. I just wanted to ask you Abbey what the dwell time will be for the ventilation extract system ? and what type of filters will be used within the kitchen ventilation extract system to remove fats, grease and odour from the cooking on site?
Many thanks.

Kind Regards
Nick Howard
SEHO

Sent from my iPad

On 22 Jun 2017, at 10:46, Abbey Kelsey [REDACTED] wrote:

Hi Nick,

I am emailing in regards to the above application at Butlin's,

The information attached above in the email is requesting technical data for the kitchen extract system, obviously previously a paragraph was sent in regards to the equipment as below and drawings were sent explaining the layout.

There are two systems one for the fryers and one for the extract can you please advise exactly what information is needed to settle the application,

I will follow up with a phone call,

Many thanks,

The extract system serving the canopy provided by ourselves incorporates an in line cased axial fan unit located within the ceiling space above the take away outlet. The fan is installed with a 2 diameter length podded silencer to the inlet side to reduce airborne noise passing back to the extract hood some 17 meters from the fan location and a 2 diameter straight

through silencer installed on the discharge side. The discharge duct passes through the structure to then rise vertically 7 metres to its discharge position which is approximately 10 metres above the external ground level. The sound generally projects from the discharge vertically and has no opposing surfaces to cause any reflection back to the area around the fish and Chip restaurant or any of the adjacent venues, we do not therefore envisage any nuisance being caused by the catering extract system.

ABBEY KELSEY
Architectural Technician

Designmanagementpartnership



Design Management Partnership Ltd, 8 Trade Street, Cardiff. CF10 5DT
This electronic message contains information from Design Management Partnership Ltd
which may be privileged or confidential.
The information is intended to be for the use of the individual(s) or entity named above. If
you are not the intended recipient be aware that any
disclosure, copying, distribution or use of the contents of this information is prohibited. If
you have received this electronic message in
error, please notify us by telephone on 

 Consider the environment. Think before you Print.

<mime-attachment>