




From: Abbey Kelsey [REDACTED]
Sent: 30 June 2017 09:39
To: Simon Davis; Nick Howard
Cc: Nigel Lloyd
Subject: BR/98/17/PL - Bognor - Fish'n' Chips

Hi Simon and Nick,

Please find attached and below information in regards to fryer and ventilations details,

'The kitchen ventilation does not contain odour filtration and so does not have a dwell time for odour catchment. The filters within the kitchen canopy are inclined baffle type to provide grease capture and to prevent flame carryover in to the extract ductwork.

Let me know if you require anything else,

Regards,

ABBHEY KELSEY
Architectural Technician


Designmanagementpartnership



Design Management Partnership Ltd, 8 Trade Street, Cardiff. CF10 5DT

This electronic message contains information from Design Management Partnership Ltd which may be privileged or confidential.

The information is intended to be for the use of the individual(s) or entity named above. If you are not the intended recipient be aware that any disclosure, copying, distribution or use of the contents of this information is prohibited. If you have received this electronic message in



 Consider the environment. Think before you Print.

*