

Ronnie McGregor

From: Amanda Scholes on behalf of Planning.Responses
Sent: 05 July 2017 11:20
To: Planning Scanning
Subject: FW: re- Butlins Fish and Chips restaurant application BR/98/17/PL

From: Simon Davis
Sent: 05 July 2017 11:16
To: Planning.Responses
Subject: FW: re- Butlins Fish and Chips restaurant application BR/98/17/PL

Additional Env Health comments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Nick Howard
Sent: 05 July 2017 08:38
To: Simon Davis
Subject: RE: re- Butlins Fish and Chips restaurant application

Morning Simon,

Further to my voice message yesterday I have reviewed the information again provided by Abbey and consulted the DEFRA guidance which states that such a premises would create high level of grease and odour. On my initial review of the information I could see that the baffle filters which predominantly are there to remove grease and smoke would, if working and cleaned effectively, reduce the level of grease in the canopy and duct work and hence any odour/ gases would be vented through the flue at height above the roof eaves. However reading up on baffle filters, stand alone they would not be able to address the odour. Therefore I believe that there needs to be additional controls to deal with the odour e.g's pre filters and carbon, ozone neutraliser, ESP and Ozone etc.

Kind Regards
Nick Howard
SEHO