

From: Simon Davis
Sent: 04 June 2020 10:43

Subject: BR/99/20/PL

Hi Tim,

Please see comments of our EH HMO Officer. These are mostly for information but I don't know whether you need to amend the plans re having an escape window for unit 3?

"An escape window with a sill height of not more than 1100mm from finished floor level, with an unobstructed openable area of 0.33m² and have a minimum 450mm height and 450mm width must be provided in the bedroom of unit 3."

Kind Regards

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place

T: 01903 737874
E: simon.davis@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

Sign up to our newsletter [here](#)



