

Herringtate UK Ltd
16-18 Barmes Wallis Road
Fareham
PO15 5TT

Date: 4th May 2021

Please ask for: Mrs A Gardner

Tel: 01903 737529

Your Ref:

Our Ref: CM/11/21/DOC

Dear Fryer,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under CM/21/19/PL relating to conditions 11-surface water drainage scheme, 12-discharge of flows to water courses or for the culverting, diversion, infilling or obstruction of any water course on or adjacent to site & 13-maintenance and management of surface water drainage system.

Scyld Horsemere Green Lane Climbing BN17 5QZ

Notification regarding the above application:

Condition Number 11

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

This condition is discharged in so far as submission of details relates and refers to the following plans :
- 424955-11P3 Drainage Details 1 of 2

- 42955-12P2 Drainage Details 2 of 2
- 424955- 10P4 Drainage GA

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC', followed by a small dot.

Neil Crowther
Group Head of Planning