

Ronnie McGregor

From: Amanda Scholes on behalf of Planning.Responses
Sent: 09 May 2018 08:47
To: Planning Scanning
Subject: FW: Planning Consultation on: CM/13/18/OUT

From: Laura Gibbons
Sent: 08 May 2018 11:25
To: Planning.Responses
Subject: RE: Planning Consultation on: CM/13/18/OUT

Engineers comments in respect to surface water drainage:

Please apply standard condition ENGD2B, ENGD3A, ENGD4A, ENGD5A, ENGD5B.

Soakaways must be investigated for surface water disposal.

Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE 365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location.

Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers. Supplementary guidance notes are also enclosed for information.

It is noted that a foul sewer rising main runs across the proposed site, early engagement with southern water is therefore essential.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 04 May 2018 12:19
To: Land Drainage
Subject: Planning Consultation on: CM/13/18/OUT

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town & country Planning (Development Management Procedure) (England) Order 2015 - Article 5

Outline Consent

APPLICATION CM/13/18/OUT

NO:

Registered: 2nd May
2018

Site Address: Land to West of Church Lane South of Horsemere Green Lane
Clymping

Grid Reference: 500026 101999

Description of Works: Outline application with some matters reserved for the erection of up to 300 dwellings and ancillary development comprising open space, a building within use class D1 of up to 875 square metres net, a building for A1 use having a floor area of up to 530 sq. metres net, together with open space and ancillary works, including access points, car parking and drainage arrangements, with appearance, landscaping, layout; and scale wholly reserved for subsequent approval. The access detail, showing the points of access to the development, and indicated on Bellamy Roberts drawings numbered 4724/013 and 4724/005 Rev A are access proposals to be determined at this stage of the application. For the avoidance of doubt all other access detail within the site is to be determined as a reserved matter at a later stage. Resubmission following CM/1/17/OUT. Departure from the Development Plan.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 07-JUN-18.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:
www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Claire Potts who can be contacted on telephone number 01903 737698.

Regards
Planning Officer

consultee_email
