

Susan Haley

From: [REDACTED]
Sent: 29 January 2025 13:06
To: Jane Carrington
Cc: Sam Tyler; Paul Houston
Subject: RE: Land Drainage Consent - Land adjacent Church Lane, Climping

Hi Jane

Please see the below.

Statement from Paul Cann can be used to demonstrate that no OWC's are required in relation to onsite Climping proposals.
To support discharge of watercourse condition.

Kind Regards

Marta Furdal-Karpezo
Adoptions and Utilities Coordinator



Yarmouth House,
1300 Parkway,
Whiteley,
Hampshire.
PO15 7AX



Sent: 28 January 2025 15:32

Subject: Land Drainage Consent - Land adjacent Church Lane, Climping

Hi Marta

Further to your application for Land Drainage consent , I would confirm the following observations;

1. With regard to the proposed connection to manhole S2 in Church Lane, this would not require Land Drainage Consent as you are connecting to the existing highway drainage system and not directly to a watercourse. West Sussex County Council (WSCC) Highways would need to agree such a connection – has this been agreed with them? Can you also confirm the proposed discharge rate.

Just to advise, that I see from the CCTV survey that the highway drain from S2 (MH3 on CCTV survey) to the outfall headwall at the watercourse, is noted as 450mm diameter, where as the design drawings stipulate it to be 300mm diameter. The reason I have pointed this out is that should WSCC agree this connection, the level of your proposed 300mm pipe connection will be dictated by the downstream pipe diameter (ie. to achieve a soffit to soffit connection), so its diameter should be verified

2. The new onsite ditch/swale will not require Land Drainage Consent, despite notes on the drawing stipulating that it will require consent.
3. I note on the drawings that there is a proposal to divert the A259 ditch as part of the S278 highway works. This may require Land Drainage Consent and no doubt an application will be submitted once you are in a position to do so, although at present I am unclear as to whether this application would come from yourselves or WSCC Highways who may be delivering the highway improvements?

Look forward to hearing from you further.

Regards

Paul Cann


Principal Drainage Engineer, Coastal Engineers and Flood Prevention

T: 01903 737819

E: paul.cann@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



<https://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of

the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
