



From: Sarah Featherstone [REDACTED]
Sent: 25 June 2019 12:04
To: Anita Gardner
Subject: Re: CM/28/19/DOC and CM/27/19/DOC - Climping Mill, Climping Street

Dear Anita

Thank you for your email with queries from the conservation officer, i can confirm as follows:

- Yes all windows are 14mm slimline as indicated on drawing 09 001 and in accordance with the approved application. The new glazed patio doors WG.01 & WG.04 were not referred to as having 14mm slimline dgu in the approved application and we show these to have 24mm standard DGU's as we think it will be difficult get 14mm slimline for these large glass sizes. If you think this may be problematic please let us know and we will investigate further.
- The finish of the external windows and doors are indicated as oiled oak on the DOC drawings and we did not envisage them being stained black, but are happy to change to black stain timber if preferred.

Please let me know if any changes or further information is required for approval of these conditions.

Best
Sarah

Sarah Featherstone BA Hons Dip Arch RIBA
Director
Featherstone Young Architects

[REDACTED]
London office:
25 Links Yard, Spelman Street
London E1 5LX

Brecon office:
Ty Hedfan, Pontfaen
Powys LD3 9RR



*Habitat House for Lower Mill Estate
Sunday Times & BHA Housing Awards Winner 2016*

On 24 Jun 2019, at 16:04, Anita Gardner <Anita.Gardner@arun.gov.uk> wrote:

Dear Ms Featherstone,

I refer to the above applications and can advise that the Conservation officer has requested the following clarification:

- it is not clear if the glazing is slimlight or standard thickness. The approved application refers to 14 mm slimline double glazing. Do the drawings provided as part of the DOC correspond with that approval?
- With regard to application CM/28/19/DOC please also confirm whether the details of colour provided, will this be used on the windows as well?

I would appreciate your response within the next 10 days.

Regards

Anita Gardner

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

