

Ian Clark

Subject: FW: Climping, Horsemere - PLANNING TRACKER.

From: Robert Hodges <[REDACTED]>
Sent: 18 June 2020 17:01
To: Michael Hartnett [REDACTED]; Kazys Narbutas Consulting [REDACTED]
Cc: Mahmud Choudhury [REDACTED] Sylvia Rowbotham [REDACTED]; Rachel [REDACTED]
Subject: RE: Climping, Horsemere - PLANNING TRACKER.

This email originated from outside Carlton Design.

Our Ref: RAH/rah/CCL03279.020

Langford, Horsemere Green Lane, Climping

Dear Mike,

Further to your recent emails we comment as follow:

Potable Water Pipes

On the basis of the comment from Premier Energy, it is understood that Portsmouth Water "have advised that they are currently basing their quote on a barrier pipe system as no contamination test results have been provided in the attached study".

It is our understanding that a Water Supply Application Form is required to be submitted. This document should include a Risk Assessment in relation to potential contamination. For this site, we consider the Risk Assessment can be completed, without the need for contamination testing, to demonstrate that a barrier pipe system is not required. If you would like us to complete the relevant sections on your behalf please let me know.

Planning Condition 20

It is considered that submission of our Ground Investigation Report should be sufficient for the discharge of this condition. If there are any comments from the Contaminated Land Officer following submission of the report it is recommended that they be forwarded to us for review.

We trust that these comments are of assistance.

Kind regards

Robert Hodges

Managing Director

Crossfield
CONSULTING
GEOTECHNICAL ENVIRONMENTAL

The Granary, White Hall Farm
Long Itchington, Warwickshire, CV47 9PU

At this exceptional time, there is no one in the office to accept landline calls,
so please contact me by email or my mobile [REDACTED]
until the situation improves

[REDACTED]