

Architectural Drawing Reference:

Important

Do not scale, use figured dimensions only.

All dimensions to be verified on site prior to the commencement of any work or the production of any shop drawing. All discrepancies to be reported to the Architect.

This drawing is to be read in conjunction with all related Architect's and Engineer's drawings and any other relevant information.

Note(s):
DRAWING NOTES:

PLEASE ENSURE 3C&E LINKS ARE PROVIDED BETWEEN BOARDS THAT HAVE EXTERNAL LIGHTING CIRCUITS.

PLEASE ENSURE TIMER CLOCKS ARE INSTALLED. DEFAULT OPERATION TO BE 11PM - 7AM

LIGHTING COLUMNS TO BE 4M IN HEIGHT.

BUILDING MOUNTED LIGHTS TO BE INSTALLED AT 2.5M

CAR CHARGING POINTS TO BE WIRED BACK TO MAIN PANEL BOARD ON SEPARATE RADIALS (10MM)

CCTV WIRED IN CAT6. CAMERAS TO BE MOUNTED AT 2.5M

Rev	Description	Date
Rev P1	Issued for comment/approval.	26/11/21

Client:
BRACKLEY

Project:
LITTLE HAMPTON

Drawing Title:
EXTERNAL WORKS LAYOUT

Scale:
1:200@A1

Drawn By:
AAB

Checked By:
-

Project No.:
LHP/10/21

Drawing No.:
800

Revision:
P1

monitor systems

POSITIVE ELECTRICAL SOLUTIONS

174 Chester Road, Greenbank, Northwich, Cheshire, CW8 4AL.

Tel: 01606 782 727 Fax: 01606 782 225
Email: sparks@monitor-systems.com
Website: www.monitor-systems.com

