

Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2019/121479/01-L01
Your ref: CM/33/19/PL
Date: 01 August 2019

Dear Sir/Madam

DEMOLITION OF 1 NO. EXISTING DWELLING & ERECTION OF 1 NO. NEW DWELLING

ATHERINGTON LODGE CLIMPING STREET CLIMPING BN17 5RN

Thank you for the consultation on the above application, please quote our reference on all correspondence.

Environment Agency position

In the absence of an acceptable Flood Risk Assessment (FRA) we **object** to this application and recommend that planning permission is refused.

Reason(s)

The submitted FRA does not comply with the requirements for site-specific flood risk assessments, as set out in paragraphs 30 to 32 of the Flood Risk and Coastal Change section of the planning practice guidance. The FRA does not therefore adequately assess the development's flood risks. In particular, the FRA fails to:

- Clearly state finished floor levels – To ensure the safety of occupants, these must be above future flood levels with allowances for climate change, especially as all sleeping accommodation is located on the ground floor
- consider how people will be kept safe from the identified flood hazards
- consider how a range of flooding events (including extreme events) will affect people and property
- consider the requirement for flood emergency planning including flood warning and evacuation of people for a range of flooding events up to and including the extreme event.

Environment Agency
Canal Walk, ROMSEY, Hampshire, SO51 7LP.



Overcoming our objection

To overcome our objection, the applicant should submit a revised FRA which addresses the points highlighted above.

If this cannot be achieved, we are likely to maintain our objection. Please consult us on any revised FRA and we will respond within 21 days of receiving it.

Advice to Local Planning Authority

We do not normally comment on or approve the adequacy of flood emergency response procedures accompanying development proposals, as we do not carry out these roles during a flood. Our involvement with this development during an emergency will be limited to delivering flood warnings to occupants/users covered by our flood warning network.

The planning practice guidance to the National Planning Policy Framework states that, in determining whether a development is safe, the ability of residents and users to safely access and exit a building during a design flood and to evacuate before an extreme flood needs to be considered. One of the key considerations to ensure that any new development is safe is whether adequate flood warnings would be available to people using the development.

In all circumstances where warning and emergency response is fundamental to managing flood risk, we advise local planning authorities to formally consider the emergency planning and rescue implications of new development in making their decisions. As such, we recommend you consult with your emergency planners and the emergency services to determine whether the proposals are safe in accordance with the guiding principles of the Planning Practice Guidance (PPG).

If you are minded to grant permission against the Environment Agency's advice, please contact the Planning Liaison Officer named below before making a formal decision to discuss the conditions and informatives that the Environment Agency would wish to apply to this proposal.

Advice to Applicant


If the Applicant would like any further detailed advice we would be happy to provide this subject to a charge.

As part of this service you would have a dedicated project manager to coordinate the advice from different teams within the Environment Agency. It would also include bespoke technical and planning advice if you request this. This will allow you to have greater clarity about the assessments you need to accompany your planning application and certainty about whether the development is acceptable to us before you resubmit.

In accordance with the Planning Practice Guidance (Ref. ID: 20150415), please notify us by email within 2 weeks of a decision being made or application withdrawn. Please provide us with a URL of the decision notice, or an electronic copy of the decision notice or outcome.

Yours faithfully

Miss Suz Greenwood
Planning Advisor, Environment Agency



End