




From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 06 August 2021 16:03

To: Anita Gardner <Anita.Gardner@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Maidenhead Aquatics Crookthorn Lane Climping BN17 5SN - CM/34/21/PL

Planning Application Reference: CM/34/21/PL

Proposal: Change of use of part of site to car wash including siting of cabin and canopy. This application may affect the setting of a listed building & is in CIL Zone 5 (Zero Rated) as other development.

Address: Maidenhead Aquatics Crookthorn Lane Climping BN17 5SN

Dear Anita,

Environmental health has no objection in principle to the above proposal, however the following matters must be considered.

Noise

I note from the application that the nearest residential property is approximately 45 meters from the location for the proposed car wash.

Construction work shall not commence unless and until an impact assessment of the noise from the development on nearby residential properties has been completed and submitted in writing to the Local Planning Authority. The impact assessment shall include noise from deliveries and operation of the development and shall include a noise mitigation scheme.

The assessment shall have regard to the principles of BS 4142:2014 and achieve a difference between the measured 'rating' level and the measured 'background' level of at least 5dB(A). A test to demonstrate compliance with the noise mitigation scheme shall then be undertaken by a competent acoustician / consultant before the use commences.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Construction – Small Developments

The development shall be carried out in accordance with the 'Arun District Council Construction Code of Practice: For small developments in Arun', available from:

<https://www.arun.gov.uk/download.cfm?doc=docm93ijjm4n12193.pdf&ver=12201>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Thank you for your consultation,

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

