



Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Your Ref
CM/37/18/OUT
Our Ref
PLAN-026164
Date
15/01/2019

Dear Sirs,

Proposal: Outline application with some matters reserved for the redevelopment of site with 2 no. 4-bed detached bungalows & associated works (resubmission following CM/10/18/OUT). This application is a Departure from the Development Plan.

Site: Mistletoe Farm, Horsemere, Green Lane, Climping, BN17 5QZ.
CM/37/18/OUT

Thank you for your letter of 17/12/2018.

Please find attached a plan of the sewer records showing the approximate position of foul sewer crossing the site. The exact position of the foul sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

It might be possible to divert the foul sewer, so long as this would result in no unacceptable loss of hydraulic capacity, and the work was carried out at the developer's expense to the satisfaction of Southern Water under the relevant statutory provisions.

Should the applicant wish to divert apparatus:

1. The 150 mm diameter foul sewer requires a clearance of 3 metres either side of the sewer to protect it from construction works and allow for future access for maintenance. No development or new tree planting should be located within 3 metres either side of the external edge of the public sewers.
2. No new soakaways should be located within 5 metres of a public sewer.

3. All other existing infrastructure should be protected during the course of construction works.

Alternatively, the applicant may wish to amend the site layout, or combine a diversion with amendment of the site layout. If the applicant would prefer to advance these options, items (1) – (4) above also apply.

Please note there is Decommissioned foul rising main within the site. If the foul rising main should be found during construction works, the applicant should contact Southern Water Services before any further works commence on site.

Furthermore, due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

In order to divert drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example, "The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to divert the public sewers, prior to the commencement of the development."

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW [REDACTED] or www.southernwater.co.uk.

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW [REDACTED] or www.southernwater.co.uk. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Yours sincerely,



Luis Silva
Developer Services

[illegible]