

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 26 August 2021 10:23

To: Anita Gardner <Anita.Gardner@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: FW: EMAQ guidance - Commercial extraction system

Planning Application reference: CM/43/21/DOC

Proposal: Approval of details reserved by condition imposed under CM/16/21/PL relating to conditions 6-details of proposed grease trap/separator, 7-extraction details & 8-boundary treatments to southern & western boundary.

Address: Bairds Farm Shop, Crookthorn Lane, Climping, Littlehampton, West Sussex, BN17 5SN

Dear Anita,

Please see the below emails from Sam Hughes of Bald Kitchen Ltd.

I am satisfied that the submitted information demonstrates that the proposed extraction system has a suitable level of odour control for the commercial kitchen operation proposed, and that noise levels at the nearest dwelling shall be within WHO recommendations for external amenity areas.

I therefore recommend discharge of condition 7 (extraction details)

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: sam hughes [REDACTED]
Sent: 25 August 2021 19:10
To: Craig Milligan <Craig.Milligan@arun.gov.uk>
Subject: Re: EMAQ guidance - Commercial extraction system

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hello Craig

Thank you for your time earlier.

Please see below the assessment completed via appendix 3 risk assessment of odour.

Dispersion - 5

Proximity Of Receptors - 5

Size Of Kitchen - 5

Cooking Type - 4

Total Score - 19

Please see the above scores.

If there's any more information I need to provide please email or call me.

I hope this gives a better insight into the premise.

Regards Sam

From: sam hughes [REDACTED]
Sent: 25 August 2021 16:17
To: Craig Milligan <Craig.Milligan@arun.gov.uk>
Subject: Re: EMAQ guidance - Commercial extraction system

Hello Craig

I will get the risk assessment sorted ASAP for you here's the spec of what we have and how many sittings we estimate per day

Estimated sittings per day 100-200

This is a rough estimate as we don't know how busy we will be.

Size of canopy

The canopy is 4m long by 1m wide 500 at the back tapers up to 300 front

Grease carbon filters qty x8

Size of filters 400mm by 400mm

800mm vapour gas lpg grill

X1 450mm twin lpg gas fryer

X1 LPG potato oven

X1 800 lpg flat top grill

If at any point you would pop down this could be helpful.

Warm regards Sam

On Wed, Aug 25, 2021 at 4:01 PM Craig Milligan <Craig.Milligan@arun.gov.uk> wrote:

Hi Sam,

Please find the EMAQ guidance attached which includes the risk assessment for odour control requirements in appendix 3.

Please complete the risk assessment and provide me with your final score and breakdown e.g. height of stack score, distance from nearest receptor score, size of kitchen score and type of cooking score.

This shall inform the odour control requirements, including the required residence time in the carbon filter.

Please then consult your extraction system provider and have them confirm the residence time of the carbon filters you have installed.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Services



T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)

Business Support during Coronevirus click [here](#)

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
