

To register to receive notification of planning applications in your area please go to
www.arun.gov.uk/planning

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**



From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>

Sent: 09 February 2021 12:05

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Anita Gardner <Anita.Gardner@arun.gov.uk>; Laura Gibbons <Laura.Gibbons@arun.gov.uk>; Paul Cann <Paul.Cann@arun.gov.uk>

Subject: RE: Planning Consultation on: CM/53/20/PL

Engineers Comments Regarding Surface Water Drainage

At this stage no serious consideration has been given as to how to drain surface water from the site. Within the Flooding and Drainage Statement the applicant states that they are happy for this to be dealt with via condition, understanding the necessity for winter groundwater monitoring and infiltration testing. The applicant expects to drain the site via soakaways in the property gardens, or in shallow soakaways and permeable paving if groundwater is evidenced at shallow depth.

Ground investigation results from neighbouring sites evidence that infiltration is highly unlikely to be suitable at this location due to the presence of high groundwater (0.3mbgl). Therefore, a connection to the watercourse along Horsemere Green Lane is likely to be required. It is unclear how this will be possible as the site is land locked and the shallow falls across the site to the watercourse. We note that the site access is via the proposed development at Scyld. We would therefore suggest that the two sites will require a drainage scheme that works together, however the drainage scheme for Scyld as it currently stands would not have capacity to drain any additional water.

Therefore I wish to lodge a holding objection to this application.

To overcome our holding objection we request that the applicant submits details of how they propose to drain the site in a worst case/no infiltration scenario. If this information is not provided prior to determination it is likely that the layout will unduly bias the design of surface water drainage and could result in flooding being increased elsewhere.

However, if you are minded to approve the application please ensure the following conditions are applied:

PCENG D2

“Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.”

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

And the accompanying informative:

INFORM D

“Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers.

Supplementary guidance notes regarding surface water drainage are located here

<https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available on Arun District Councils website, this should be submitted with a Discharge of Conditions Application.”

PCENG D4

“Development shall not commence until full details of the maintenance and management of the surface water drainage system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The manual is to include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life. Upon completed construction of the surface water drainage system, the owner or management company shall strictly adhere to and implement the recommendations contained within the manual.”

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition to ensure that the future maintenance and funding arrangements for the surface water disposal scheme are agreed before construction commences.

Kind Regards

Sarah Burrow

Engineering Assistant, Engineering Services



Whilst national restrictions are in place I will be working flexibly between the hours of 8am and 8pm. I appreciate your patience if I am slower than usual to respond. Equally I understand that you may be facing similar challenges and varying work patterns and will not be expecting immediate responses to my e-mails.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 21 December 2020 11:34

To: Land Drainage [REDACTED]

Subject: Planning Consultation on: CM/53/20/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: CM/53/20/PL

Registered: 17th December 2020

Site Address: Land at Wren Cottage Horsemere Green Lane Climping BN17 5QZ

Grid Reference: 499689 102182

Description of Works: Development of 2 No 2-bed & 2 No 3-bed detached dwellings & associated works. This site is in CIL Zone 3 and is CIL Liable as new dwellings.

The Council have received the above application.

[Click here to view the application details](#)

This application has been identified as CIL Liable. Therefore please be aware that, in accordance with Appendix 2 of the Arun CIL Charging Schedule, your consultation response should only include requests for Section 106 for onsite mitigation, Pagham Harbour Management Contributions (if applicable) or Affordable Housing. Off Site mitigation measures directly related to this development should be dealt with by condition if possible to ensure the scaling back of Section 106 if possible. CIL contributions will be used for off site infrastructure mitigation schemes. Therefore if this proposal triggers the need for off site mitigation, please ensure that you engage in the CIL Infrastructure List Consultation process upon receipt of a consultation letter.

Should you have any comments to make, these should be sent by replying to this email by 28th January 2021. You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website <https://www.arun.gov.uk/development-plan> as can the the leaflet how to respond to planning applications <https://www.arun.gov.uk/planning-application-comments> which deals with material planning considerations.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Mrs A Gardner

Planning Officer- Arun District Council

Telephone: 01903 737529

Email: Anita.Gardner@arun.gov.uk

PLCONSULT (ODS) 2020