

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 29 October 2021 13:55

To: Anita Gardner <Anita.Gardner@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 1-4 The Piglets Climping Street Littlehampton BN17 5RG - CM/53/21/PL

Planning Application Reference: CM/53/21/PL

Proposal: Installation of ground source heat pump to provide heating and hot water to 4 No. Holiday Lets. This application is in CIL Zone 5 (zero rated) as other development

Address: 1-4 The Piglets Climping Street Littlehampton BN17 5RG

Dear Anita,
Environmental Health has no objection to the above proposal, however the following matter must be considered.

Noise

The noise level from the ground source heat pump and associated plant shall not exceed 50dB (A) at the façade of the nearest residential dwelling.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely,
Craig

Craig Milligan
Environmental Health Officer, Technical Service

T: 01903 737670
E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

