



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
CM/55/20/PL

Our ref
PLAN-037604

Date
04/03/2021



Dear Sir/Madam,

Proposal: Variation of condition 2-plans condition imposed under CM/21/19/PL to omit the detached garage serving units 5 and 6 and provide these two units with an attached garage allowing a sewer diversion to run between the units ensuring a 3m easement either side of the sewer in accordance with Southern Water requirements.

Site: CM/55/20/PL: - Scyld Horsemere, Green Lane, Climping, BN17 5QZ.


Thank you for your letter dated 09/02/2021.

Southern Water does not recommend variation of condition 2 until the developer submits the detailed plan showing the 3 metres easement to the existing public foul sewer. Kindly submit a detailed plan, clearly indicating the 3 metres easement on either side of the public foul sewer.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX

Website: southernwater.co.uk

Yours faithfully,



Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366870