

Zac Denton

From: Zac Denton
Sent: 26 April 2019 08:58
To: 'Emma Weaver'
Cc: David Fuller; Laura Gibbons
Subject: RE: Apple Barn Cottage - CM/5/19/HH

Dear Emma,

Thank you for forwarding the information.

The Drainage Engineer has commented as follows:

"There is still a lack of calculations. Can these please be supplied?"

Further information has been provided about the depth of infiltration tests and the rates at each testing location. I would like to see the test result from BH3 used in design of G1 soakaway. And the infiltration rate of BH2 at 929mm depth used in the design of G2 soakaway. These results are those that most accurately reflect the location and depth of the proposed soakaways."

Many thanks,

Zac

From: Emma Weaver [REDACTED]
Sent: 18 April 2019 15:00
To: Zac Denton
Cc: David Fuller; Laura Gibbons
Subject: Re: Apple Barn Cottage - CM/5/19/HH

Dear Zac

David is away on annual leave this week and next. In his absence I have forwarded the comments to the drainage engineer and hope the attached answers / addresses Lauras comments.

Kind regards
Emma

Emma Weaver BSc (Hons)
Partner

10 - 11 The Parade
Willowhayne Crescent
East Preston
West Sussex
BN16 1NS

www.fuller-associates.co.uk

This electronic message contains information that may be privileged and confidential. The information is intended to be for the use of the individual(s) named above. If you are not the intended recipient, please be aware that any disclosure, copying, distribution or use of the contents is prohibited. If you have received this message in error, please delete it and notify me immediately.

General Data Protection Regulations

In order to comply with the General Data Protection Regulations any personal information such as name, postal address, telephone number, and email address given will only be used to provide a requested service and will not be disclosed to any other third party without your prior permission or unless we are required to do so by law.



From: Zac Denton [REDACTED]
Date: 17 April 2019 at 08:47:02 CEST
To: [REDACTED]
Subject: RE: Apple Barn Cottage - CM/5/19/HH

Dear Mr Fuller

The Council's Drainage Engineer requires further details, please can you provide these.
Please see below.

Kind regards,

Z Denton

From: Laura Gibbons
Sent: 16 April 2019 15:44

To: Zac Denton
Subject: RE: Apple Barn Cottage - CM/5/19/HH

Hi Zac,

Please can we get the surface water drainage calculations supplied to support the proposed design.

Please can the applicant also submit further details of the infiltration testing. I note that the layout states that an average rate has been used in design. Please can the depths of infiltration testing and results be supplied to ensure that the infiltration rate used in design is appropriate.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

From: Zac Denton
Sent: 10 April 2019 08:44
To: Laura Gibbons
Subject: FW: Apple Barn Cottage - CM/5/19/HH

Hi Laura,

Please can you look at these details.

Kind regards,

Zac

From: David Fuller [REDACTED]
Sent: 09 April 2019 14:08
To: Zac Denton
Cc: [REDACTED]
Subject: Apple Barn Cottage - CM/5/19/HH

Dear Mr Denton,

Please find attached the surface water drainage design based on infiltration testing as previously discussed.

I assume you will request an extension of time to allow consultation with your drainage engineer, and look to determine the application shortly after receipt of her response.


I look forward to hearing from you.

Kind regards

David Fuller BSc (Hons) MRICS
Partner

<image001.png>

10 - 11 The Parade
Willowhayne Crescent
East Preston
West Sussex
BN16 1NS



www.fuller-associates.co.uk

This electronic message contains information that may be privileged and confidential. The information is intended to be for the use of the individual(s) named above. If you are not the intended recipient, please be aware that any disclosure, copying, distribution or use of the contents is prohibited. If you have received this message in error, please delete it and notify me immediately.

General Data Protection Regulations

In order to comply with the General Data Protection Regulations any personal information such as name, postal address, telephone number, and email address given will only be used to provide a requested service and will not be disclosed to any other third party without your prior permission or unless we are required to do so by law.

<image002.png>

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
