

26/11/2021

App: CM/60/21/DOC

Proposal: Approval of details reserved by condition imposed under ref CM/13/19/RES relating to Condition Nos 5 - car parking, 6 - covered & secure cycle parking, 7 - external lighting and 9 - windows or other openings in roofs.

Address: Mistletoe Farm Horsemere Green Lane Climping BN17 5QZ

Condition 7

We note the lighting scheme has downward directional luminaires to retain darkness, which complies with best practice advice. However, we require the scheme to confirm that the lamp specification fulfils with the below:

- LED luminaires
- A warm white spectrum (ideally <2700Kelvin) should be adopted to reduce blue light component.

Kind Regards

Jen



Jennifer Pollitt
Environment Officer
Environment
Chichester District Council

<http://www.chichester.gov.uk>