

From: Laura Gibbons
Sent: 03 May 2018 15:31

Cc: Simon Davis; Paul Cann
Subject: RE: 97 Barnham Road, Eastergate - EG/107/17/DOC

Gerald,

We have reviewed the documents you have provided and have the following comments:

- Thrust blocks need to be provided on the rising main.
- Where the depth of the rising main is less than 0.9m we require the pipe to have a concrete bed and surround or concrete protection slab to be provided.
- A discharge manhole needs to be provided a minimum of 10m from the connection to the foul water main. With a length of gravity main in between at a suitable gradient, with a vertical back drop if greater fall is required.

We understand that Southern Water are still investigating the status of the pipe to the South West of the development.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.