

From: Simon Davis
Sent: 08 June 2018 11:39
To: Planning.Responses
Subject: FW: 97 Barnham Road, Eastergate - EG/107/17/DOC

Further drainage comments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 08 June 2018 11:04
To: Simon Davis
Subject: RE: 97 Barnham Road, Eastergate - EG/107/17/DOC

Simon,
Yes you had sent the comments to me. Sorry, I didn't copy you in on my response. Apologies.
I responded on Monday with the following:

Gerald,
Sorry for the delay in getting back to you. I have reviewed the responses you have provided.
On this occasion, we will let the lack of thrust blocks and cover depths be permitted.
However, we need to see an additional manhole and length of gravity pipe (to be laid at an agreed gradient) at the downstream extent of the rising main. Not including this could result in serious problems with backing up of foul water and blockages occurring as a result.
Regards,

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



From: Simon Davis
Sent: 08 June 2018 10:05
To: Laura Gibbons
Subject: RE: 97 Barnham Road, Eastergate - EG/107/17/DOC

Hi Laura,

Have I already sent the attached response to your 03/05/18 comments over to you? I thought I had done but maybe as you have not responded, I did not.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.