

ARUN DISTRICT COUNCIL

10 MAY 2013

RECEIVED

Atkins LimitedAnglo St James House
39A Southgate Street
Winchester
Hampshire SO23 9EH**Telephone +44 (0)1962 858688****Fax +44 (0)1962 810296****winchester.enquiries@atkinsglobal.com****www.atkinsglobal.com**

Planning and Development Services
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your Ref: EG/15/13/

Our Ref: PLAN-002968

09/05/2013


Proposal: Dropped kerb and driveway to front of property.**Site: 20 Gospond Road Barnham PO22 0EU.****EG/15/13/**

Dear Sir,

Thank you for your letter of 16/04/2013.

Southern Water has no objection to the above proposal.

There are no public surface water sewers in the area to serve this development. Alternative means of draining surface water from this development are required. This should not involve disposal to a public foul sewer.



Developer Services