

From: Amanda Scholes on behalf of Planning.Responses
Sent: 17 April 2019 11:14
To: Planning Scanning
Subject: FW: Planning Consultation on EG/27/19/DOC

From: Laura Gibbons
Sent: 17 April 2019 09:02
To: Planning.Responses
Cc: Amber Willard
Subject: RE: Planning Consultation on EG/27/19/DOC

Engineers Comments Regarding Condition 3

I recommend that condition 3 is discharged based on the supplied information.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: [planning.responses](#)
Sent: 10 April 2019 10:39
To: Land Drainage
Subject: Planning Consultation on EG/27/19/DOC

To: Engineers (Drainage)

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION EG/27/19/DOC
NO:

Registered: 08-APR-19
Site Address: 29 Elm Grove Barnham

Description of Works: Approval of details reserved by condition imposed under ref EG/72/18/HH relating to Condition No 3 surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 24th April 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Amber Willard who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
