

Daun Johnson

From: Simon Power
Sent: 08 October 2009 17:32
To: Planning.Responses; Jonathan Parsons
Cc: Brian Holland; 'Hailey, Phil'
Subject: FW: Planning Consultation on: EG/46/09/DOC at 12 Downview Road, Barnham

[Drainage Engineers comments.](#)

[Condition 9 - In respect of Appeal Decision APP/C3810/A/07/2059083.](#)

- i) Details of the responsibilities of each party etc have not been submitted.
- ii) Details of the maintenance and management of the surface water drainage scheme etc have not been submitted.

[This condition should not be discharged.](#)

From: Brian Holland
Sent: 02 October 2009 09:48
To: Simon Power
Subject: FW: Planning Consultation on: EG/46/09/DOC at 12 Downview Road

[Did you get this one?](#)

B

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 24 September 2009 10:31
To: Brian Holland
Subject: Planning Consultation on: EG/46/09/DOC at 12 Downview Road

To: Engineering Services Manager

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION **EG/46/09/DOC**
NO:

Registered: 18-SEP-09
Site 12 Downview Road Barnham PO22 0EG
Address:

Description of Application for Discharge of condition no's 2, 3, 4, 8 and 9
Works: relating to EG/15/07/

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 8th October 2009. You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr J Parsons who can be contacted on

telephone number 01903 737773.

Thanking you in anticipation

Planning Case Officer

post_con_email
