

From: Thomas Callaway
Sent: 18 November 2013 11:58
To: Peter Cleveland; Planning.Responses
Subject: EG/53/13/DOC

Peter

Apologies I no longer have the original consultation email for EG/53/13/DOC.

Conditions 16 – 19 of the above application are recommended for discharge. An inspection of structures such as the headwalls will be carried out once they are implemented.

Further groundwater monitoring is not required due to no infiltration on site and a suitably lined basin.

Condition 15 should be discharged once you are satisfied that the scheme will be approved and permitted by the EA.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.