



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning & Building Control General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Barratt & David Wilson Homes Southampton
Tollbar House
Tollbar Way
Hedge End
Southampton
SO30 2UH

Your Ref: EG/53/13/DOC

Please ask for:

Mr P Cleveland

20 November 2013

Dear Sir/Madam

Article 21 of the Town and Country Planning (General Development Procedure) Order 1995
Application for approval of details reserved by conditions 3, 5, 7, 8, 9, 10, 13, 15, 16, 17, 18, 19 25, and
28, following a grant of planning permission EG/29/13.
Former Brooks Nursery Eastergate,,

Notification regarding the above application:

Condition Number 8

No development including site access, demolition or associated construction activities, shall take place on the site unless and until all the existing trees/bushes/hedges to be retained on the site have been protected by a fence in accordance with BS5837 (2012) and Section 9, to be approved by the Local Planning Authority for erection around each tree, group of trees and vegetation to a distance of 15m or to the Root Protection Area (RPA) as calculated in accordance with Table 2 of BS5837 (2012) to be agreed in writing by the Local Planning Authority.

Within the areas so fenced off the existing ground must not be cultivated, nor must it be lowered or raised or added to by the importation and spreading of top soil unless agreed by the Local Planning authority. There must be no materials, temporary buildings, plant machinery or surplus soil placed or stored thereon without prior written approval of the Local Planning Authority.

No trenching should occur within the protective fencing surrounding the Root Protection Area. If however there is no alternative but to locate the services then its encroachment into the Root Protection Area must be kept to a minimum and where the roots should be exposed using compressed air technology, such as the air spade to reduce damage caused by mechanical methods. If roots requiring severance to allow for the passage of services is necessary then an arboriculturist would be required to assess and determine whether the loss of the roots would be detrimental to the continued health and stability of the affected tree.

Reason: To ensure the retention and maintenance of trees and vegetation which is an important feature of the area in accordance with policy GEN7 of the Arun District Local Plan.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

A 'Tree Protection Plan' (Drawing No. BSH18222-03b) has been submitted to identify all trees to be retained and protected during construction. The means of protection specified within docdeci

Tree Protection Plan was inspected by the Councils Arborist on 6th November 2013, and was considered to be acceptable. The Condition is therefore discharged on this basis.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours faithfully

A handwritten signature in black ink, appearing to read 'KARL', with a long, sweeping horizontal line underneath.

Karl Roberts
Assistant Director Planning & Economic Regeneration