

From: Thomas Callaway
Sent: 25 November 2013 13:37
To: Peter Cleveland
Subject: RE: EG/53/13/DOC

Hi Peter

Consent for discharge into the watercourse is granted now that we have received details and calculations proving that the rate of discharge to the watercourse will be no greater than greenfield runoff rates. This was supplied for the discharge of Condition 16 and provides sufficient information for the discharge of Condition 17.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, [Arun District Council](#) | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: Peter Cleveland
Sent: 25 November 2013 13:33
To: Thomas Callaway
Subject: RE: EG/53/13/DOC

Hi Tom

I just wanted to clarify a point for the file on Condition 17, to satisfy the Condition, formal consent is required in writing from the Lead Local Flood Authority (WSCC) or its agent (ADC) for the discharge of any flows to watercourses, or the culverting, diversion, infilling or obstruction of any watercourse on the site.

Please could you confirm that by approving Condition 16 that your response affectively provides the formal consent for the discharge into a watercourse?

Kind regards
Peter

Peter Cleveland MSc | Senior Planner, Planning Department, Arun District Council | Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37631 | External: +44 (0) 1903 737631 | E-mail: Peter.Cleveland@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Thomas Callaway
Sent: 18 November 2013 15:44
To: Peter Cleveland
Subject: RE: EG/53/13/DOC

Apologies, I missed that one. Condition 28 is also recommended for discharge.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: Peter Cleveland
Sent: 18 November 2013 15:39
To: Thomas Callaway
Subject: RE: EG/53/13/DOC

Hi Tom

Thank you for the formal agreement of Conditions, can condition 28 also be formally discharged?

Kind regards
Peter

From: Thomas Callaway
Sent: 18 November 2013 11:58
To: Peter Cleveland; Planning.Responses
Subject: EG/53/13/DOC

Peter

Apologies I no longer have the original consultation email for EG/53/13/DOC.

Conditions 16 – 19 of the above application are recommended for discharge. An inspection of structures such as the headwalls will be carried out once they are implemented.

Further groundwater monitoring is not required due to no infiltration on site and a suitably lined basin.

Condition 15 should be discharged once you are satisfied that the scheme will be approved and permitted by the EA.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk

 Save the environment - think before you print.