

From: John Green
Sent: 30 October 2012 12:04
To: Susan Leeson
Cc: Planningecons; Graham Evans
Subject: RE: EG/59/12

Susan,

I have viewed EG/59/12 and make the following comments:

There is potential for noise affecting nearby residential premises. The information provided on sound power levels gives 3 sets of sound data, the first of which is significantly louder than the second two. It is unclear when the first set of sound power levels applies and under what circumstances. I would therefore object to the application unless further clarification is provided. I note that the fence surrounding the a/c units is described as "hit and miss" and I therefore assume that this will have gaps and thus offer negligible noise reduction.

No information is provided as to the hours of use and whether the premises might be used for activities such as amplified musical entertainments which might give rise to noise disturbance. Without further clarification I cannot support approval

Regards

John Green

John Green | Principal Environmental Health Officer, Environmental Health, Arun District Council | Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37693 | External: +44 (0)1903 737693 | E-mail: John.Green@arun.gov.uk

Visit Environmental Health's web site at www.arun.gov.uk/eh

From: Susan Leeson
Sent: 29 October 2012 11:18
To: John Green
Subject: EG/59/12

John

Please can you comment on the noise from singing on the adjacent property.

Thanks
Susan

