
From: Paul Cann
Sent: 14 December 2012 16:04
To: Planning.Responses
Cc: Janice Chapman
Subject: EG/68/12 - 73 Elm Grove, Barnham

Engineers comments;

It is noted that surface water will be discharged to soakaways. Please apply condition ENGD2A but omit reference to groundwater monitoring. We have a monitoring borehole close to the property, and therefore that data which we have collected can be used to support the applicants soakaway design.

Please note that it is believed that this property suffers from flooding from the foul sewerage system during certain extreme rainfall events.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

[Paul Cann](#) | Senior Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: Second Floor,
Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.