

Planning and Development Services
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF



Atkins Limited
Anglo St James House
39A Southgate Street
Winchester
Hampshire SO23 9EH

Telephone +44 (0)1962 858688
Fax +44 (0)1962 810296

winchester.enquiries@atkinsglobal.com
www.atkinsglobal.com

Your Ref
EG/7/13/
Our Ref
Plan-2423
Date
11/3/13

Dear Sir

Proposal: Re-construction of garage to side of dwelling.
Site: 4 Wandleys Drive, Eastergate PO20 3SF.
EG/7/13/

Thank you for your letter of 08/02/2013.

The applicant has not stated details of the proposed means of disposal of surface water from the site. Our initial investigations indicate that there are no public surface water sewers in the area to serve this development. Alternative means of draining surface water from this development are required. This should not involve disposal to a public foul sewer.

Yc 

Developer Services