[redacted]

From: Paul Cann
Sent: 13 December 2017 15:54
To: Planning.Responses
Subject: RE: Planning Consultation on EG/91/17/DOC

Comments;

1. The design will need to be verified by winter percolation testing and groundwater monitoring. This is stipulated in the condition and I suggest that the applicant contacts us to discuss our requirements in this respect.

2. Hydraulic calculations and construction details to support the design will also be required. However, Item 1 needs to be resolved first.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at http://www.arun.gov.uk/ and www.chichester.gov.uk
Save the environment - think before you print.

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 04 December 2017 15:03
To: Paul Cann
Subject: Planning Consultation on EG/91/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO:	**EG/91/17/DOC**
Registered:	30-NOV-17
Site Address:	The White Cottage Barnham Road Eastergate PO20 3RT
Description of Works:	Approval of details reserved by condition imposed under EG/42/17/HH relating to condition 3-surface water drainage scheme.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditons relating to your field of expertise.
Click here to view the Discharge of Condition application
Click here to view conditions on original application - click on decision tab

Should you have any comments to make, these should be sent by replying to this email by 18th December 2017.

www.arun.gov.uk/planning
Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.
In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email