




From: Christopher Davis
Sent: 20 September 2018 13:27
To: [REDACTED]
Cc: Anna Appleton; Anita Gardner
Subject: RE: EP/107/18/NMA - 3 THE STREET EAST PRESTON - ASHP
Importance: High

Dear Angie

It was good to meet you on site this morning and thank you for arranging for the ASHP pumps to be running on each plot so I could make my acoustics assessments accordingly

Having assessed both plots, I can confirm that neither of the ASHP pumps create a level of noise that would be deemed a nuisance, intrusive or loud enough to create a disturbance to either the residents of the homes or the neighbouring dwellings

I have discussed my findings from the site visit with Anita Gardener following my site visit

I wish you all the very best with the development

Kind regards

Christopher Davis
Environmental Health Officer
Environmental Health Department
[REDACTED]

Arun Civic Centre | Maltravers Road | Littlehampton | BN17 5LF



From: Anna Appleton
Sent: 19 September 2018 12:23
To: Christopher Davis
Subject: FW: EP/107/18/NMA - 3 THE STREET EAST PRESTON - ASHP

Hi Chris

Did you comment on this one? If so could you respond.

Thanks

Anna

From: K.A.L HOMES LTD [REDACTED]
Sent: 19 September 2018 12:01
To: Anna Appleton
Subject: EP/107/18/NMA - 3 THE STREET EAST PRESTON - ASHP

Dear Ms Appleton,

I understand from our planning application that you have issues relating to the positioning of our ASHP units, glazing etc...

The units are mounted on Daikin approved flexi feet as designed by NC Designs on behalf of Daikin.

The glazing to both properties are in the region of 28db rw ratings with argon filled double glazed units.

The positioning of plot 1 - is the only place the unit can be positioned on the building due to the drive and wall on the other side.

Plot 2 ashp again we believe to be in a good position as the unit is the smallest that they make and it is again mounted on flexi feet.

Could you kindly telephone us for a chat to discuss this as we need to resolve these issues before selling the properties.

If you could kindly contact me as soon as possible that would be appreciated on 01903 200502

kind regards

Angie Wheatland
[REDACTED]