

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 15 January 2021 12:13

To: Andrew Wood <Andrew.Wood@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Land adjacent to Warren Recreation Ground Car Park Sea Road East Preston BN16 1JP - EP/156/20/PL

Planning Application Reference: EP/156/20/PL

Proposal: Installation of 4 No solar power operated lights, attached to four 5mtr galvanised steel columns. This site is in CIL Zone 4 (Zero Rated) as other development.

Address: Land adjacent to Warren Recreation Ground Car Park Sea Road East Preston BN16 1JP

Dear Andrew,

There is insufficient information to determine whether the proposed external lighting may potentially cause a light nuisance to neighbours. I note the proposed location of the solar power operated lights, however a lux diagram showing the spot light orientation and extent of light spill is required to assess for potential light nuisance. I therefore recommend that the applicant be required to submit a lux diagram illustrating the orientation and extent of light spill from the proposed spot lights.

Yours sincerely, Craig

Craig Milligan
Environmental Health Officer
Technical Services

T: 01903 737670

E: craig.milligan@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

Sign up to our newsletter [here](#)

