




From: [REDACTED]

Sent: 02 February 2022 13:03

To: Kathryn Welch <Kathryn.Welch@arun.gov.uk>

Subject: 11 Worthing Road, East Preston

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Kathryn,

Here are some additional photos as promised, hope they help.

I have spoken to the applicant and they are agreeable to changing the 1st floor side facing windows of bedrooms 1 & 2, to obscure glazed and fixed shut up to 1.7m above FFL. We will then nominate the velux rooflights on the front elevation to be suitable for means of escape purposes.

If you have any other questions then please let me know.

Regards.

Wayne

Wayne Gander MCIAT

Chartered Architectural Technologist

98 Durrington Lane, Worthing, West Sussex BN13 2RQ



Disclaimer:

The information contained or otherwise implied within this e-mail is confidential and may be privileged. It is for the use of the named recipient only. If you have received this message in error please notify us immediately and please destroy this message without disclosing or copying its contents to anybody.

The content of this e-mail has been provided in good faith and is deemed by the sender to be reliable and accurate. I, however, do not accept any liability in respect of this e-mail and any person acting solely on the information contained within, does so entirely at his own risk. Opinions, conclusions and other information in this message that do not relate to the official business of mine shall be understood as neither given nor endorsed by the writer.

*** NOTE - OFFICE HOURS Monday – Thursday 9.00am - 5.00pm ***













