

Folkes Architects
The Old Forge
6 Church Street
Storrington
West Sussex
RH20 4LA

Date: 8th June 2020

Please ask for: Mrs A Gardner

Tel: 01903 737529

Your Ref:

Our Ref: EP/48/20/DOC

Dear Mr Clark,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref EP/121/17/PL relating to Condition Nos 3 - materials & finishes, 4 - hard & soft landscaping, 6 - visibility splays, 7 - car parking spaces, 8 - pedestrian visibility splays, 10 - surface water drainage, 11 - SuDs, 13 - level survey and 15 - Construction Management Plan

16 Worthing Road East Preston BN16 1AZ

Notification regarding the above application:

Condition Number 10

Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.

The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.

No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

This condition is discharged in so far as submission of details relates and refers to Surface Water Drainage Statement, 7338A dated 04-06-2020, Site Drainage Details Sheet 1 of 2 7338/1701 rev P3, Site Drainage Details Sheet 2 of 2 7338/1702 P3

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish.

Neil Crowther
Group Head of Planning