Siobhan Honney-Bayes

From: Brian Holland
Sent: 16 June 2011 13:05
To: Planning.Responses
Subject: RE: Planning Consultation on: EP/63/11/DOC at Church Field

Engineer's Response:

I have no record of Engineers being requested to comment on the original planning application hence none of the conditions were at our request. I note there is no condition regarding disposal of surface water. There are no design details available therefore the suitability of the proposed soakaways cannot be checked.

Regards

Brian Holland
Engineering Services Manager
Tel 01903 737815

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 16 June 2011 11:07
To: Brian Holland
Subject: Planning Consultation on: EP/63/11/DOC at Church Field

To: **Engineering Services Manager**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO:	**EP/63/11/DOC**
Registered:	08-JUN-11
Site Address:	Church Field Station Road East Preston BN16 3AJ
Description of Works:	Application for approval of details recerved by conditions 2, 3, 7, 9, 13 and 14 imposed under EP/90/09.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditons relating to your field of expertise.
Click here to view the Discharge of Condition application

Click here to view conditions on original application - click on decision tab

Should you have any comments to make, these should be sent by replying to this email by 30th June 2011. You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning
Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Ms E Hearsey who can be contacted on telephone number 01903 737768.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email