

Lynnyrd Wolfe

From: Anita Gardner
Sent: 31 July 2019 09:23
To: Planning.Responses
Subject: FW: EP/64/19/DOC
Attachments: 4501_Marmont_EastPreston_DrainageLayout_F_REV C.pdf; 4501_Marmont_EastPreston_DrainageNetworkCalculations_F_REV B.pdf

Please treat plan as substitute and add other info to application

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Ben Daines [REDACTED]
Sent: 26 July 2019 10:21
To: Laura Gibbons [REDACTED]
Cc: Anita Gardner [REDACTED]
Subject: RE: EP/64/19/DOC

Laura,

Please find attached amended information which hopefully addresses the concerns set out in your email of 25 July.

Kind Regards

Ben Daines MRTPI
Associate Planner

ECE Planning

Planning permission has been granted for the redevelopment of the GBMC Pelham Street Campus in Brighton – click [here](#) to read more



Brooklyn Chambers, 11 Goring Road Worthing West Sussex BN12 4AP

Privacy/Confidentiality Statement
www.eceplanning.com

ECE Planning Limited, Registered in England No 07644833, Registered Office Amelia House, Crescent Road, Worthing, West Sussex BN11 1QR.

From: Laura Gibbons [REDACTED]
Sent: 25 July 2019 12:14
To: Ben Daines [REDACTED]
Subject: RE: EP/64/19/DOC

Ben,

Switching diffuser units for perforated pipe isn't sufficient. Infiltration should not occur within 5m of a building when the infiltrating structure is dealing with more water than that which is falling directly on it.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

From: Ben Daines [REDACTED]
Sent: 23 July 2019 [REDACTED]
To: Laura Gibbons [REDACTED]
Cc: Anita Gardner [REDACTED]
Subject: RE: EP/64/19/DOC

Hi Laura,

Please find attached additional drainage details which hopefully address the comments set out in your email below.

Kind Regards

Ben Daines MRTPI
Associate Planner

ECE Planning

Planning permission has been granted for the redevelopment of the GBMC Pelham Street Campus in Brighton – click [here](#) to read more



Brooklyn Chambers, 11 Goring Road Worthing West Sussex BN12 4AP

Privacy/Confidentiality Statement

www.eceplanning.com

ECE Planning Limited, Registered in England No 07644833, Registered Office Amelia House, Crescent Road, Worthing, West Sussex BN11 1QR.

From: Laura Gibbons [REDACTED]
Sent: 22 July 2019 11:52 [REDACTED]
To: Ben Daines [REDACTED]
Subject: RE: EP/64/19/DOC

Ben,

Thank you for sending over revised details, I have the following comments:

1. Please provide further details of the shallow swale, i.e. bed level and bank levels.
2. Diffuser units are located closer than 5m to buildings.
3. Please provide updated construction detail drawings.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

From: Ben Daines [REDACTED]
Sent: 15 July 2019 16:44
To: Anita Gardner [REDACTED]; Laura Gibbons [REDACTED]
Subject: FW: EP/64/19/DOC

Dear Anita and Laura,

Please find attached the additional information required to address Laura's comments in her email of 26 June regarding EP/64/19/DOC. Please also see the email below responding directly to Laura's comments in red. I trust the relevant conditions can now be discharged.

Please let me know if you have any queries.

Kind Regards

Ben Daines MRTPI
Associate Planner

ECE Planning

Planning permission has been granted for the redevelopment of the GBMC Pelham Street Campus in Brighton -- click [here](#) to read more



Brooklyn Chambers 11 Goring Road Worthing West Sussex BN12 4AP

Privacy/Confidentiality Statement
www.eceplanning.com

ECE Planning Limited, Registered in England No 07644833, Registered Office Amelia House, Crescent Road, Worthing, West Sussex BN11 1QR.

From: Marmont Developments [REDACTED]
Sent: 12 July 2019 16:08
To: Ben Daines [REDACTED]
Subject: FW: EP/64/19/DOC

Please find attached the revised drainage details.

Thanks

Adrian

From: Oliver Harvey [REDACTED]
Sent: 12 July 2019 15:53
To: Guy Lower
Cc: Marmont Developments
Subject: RE: EP/64/19/DOC

Hi Guy,

Please find attached the updated drawings and calcs to go along with the checklist we issued last week. Have also provided a response to the comments below.

1. Layouts need to clearly identify the formation and finish level proposed for permeable paving. On drawing & section detail
2. Please can invert levels and not depths be expressed at each manhole. Added
3. The size and fall of all pipes needs to be clearly labelled on the plan. Added
4. Catchpit locations need to be clearly marked on the plan. Added
5. The factor of safety used in calculations needs to be revised to be compliant with requirements set out within CIRIA. Please refer to our checklist for further information on this. Used CV=1 and FoS = 3, this increased storage with approx. 30%. Added a geocellular tank to the side of the pavement in the soft landscaping to make up for it, see section detail on drawing.
6. Please can an impermeable area plan be provided. in link
7. Please can pipe numbers used in calculations be provided on the layout to facilitate my review. Added
8. The invert level of the permeable paving modelled is incorrect. Please can a cap volume depth also be modelled. Used 0.418m cap to reflect the attenuation storage throughout the site, both in the 0.5m and 0.25m deep regions - $(55.5\text{m}^3 + 13.5\text{m}^3) / ((370\text{m}^2 + 180\text{m}^2) \times 0.3)$


Kind Regards,

Oliver

Oliver Harvey BSc (Hons) MSc | Flood Risk and Drainage Consultant

AMBIENTAL
ENVIRONMENTAL ASSESSMENT

a company of Royal HaskoningDHV



Ambiental Environmental Assessment Ltd qualify to ISO 14001 (Environmental Management System), qualify to ISO 9001 (Quality Management System), are members of CIRWM and members of UK Flood Partnership. Company registered in England & Wales; Company Number 10232346; Registered Address, Sussex Innovation Centre, Science Park Square, Brighton, BN1 9SB, UK. This email and any attachments are confidential and intended exclusively for the use of the intended recipient(s). Any views or opinions presented are solely those of the author and do not necessarily represent those of Ambiental Environmental Assessment Ltd. If you are not the intended recipient(s) please note that any form of distribution, copying or use of this email or the information in it is strictly prohibited and may be unlawful. If you have received this communication in error, please notify the sender and then delete the message and any attachments from your system. Please note that no responsibility for viruses is taken and it is your responsibility to scan this message and any attachments. Please consider the environment before printing out this email.