

[REDACTED]

From: Laura Gibbons
Sent: 20 July 2018 16:10
To: Planning.Responses
Subject: RE: Planning Consultation on EP/96/18/DOC

Engineers Comments Regarding Condition 9 and 10

The applicant has not provided winter infiltration test results to show that infiltration is not viable. Please provide these.

Groundwater levels of 1.6m are not sufficient justification to rule out infiltration.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

[REDACTED]

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

[REDACTED]

Sent: 16 July 2018 12:04
To: Land Drainage
Subject: Planning Consultation on EP/96/18/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION EP/96/18/DOC
NO:

Registered: 26-JUN-18
Site Address: Tudor Lodge 125A Sea Road East Preston BN16 1NX

Description of Works: Application for approval of details reserved by condition imposed under planning permission EP/59/17/PL (Appeal no. APP/C3810/W/17/3183667) relating to condition No. 9 (Surface

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 30th July 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
