ARUN DISTRICT COUNCIL 05/05/2018



(Planning) Knee Rail Detail

1 : 10



(Planning) Driver Terminal Unit - DTU / DCD

1 : 20



(Planning) Emergency Box - EB

1 : 20



Holophane lighting ltd.
D series 1 luminaire, 4000k, 105w, 11,000lm with forward throw optic mounted on 6m column dsx1.2.la114.fw
For details please see attached manufacturers data submitted with the application

(Planning) Lighting Column

1 : 50





Dome CCTV camera Panasonic WV-CW960 Series
For details please see attached manufacturers data submitted with the application

(Planning) Dome CCTV / AMPR

1 : 50



Typical detail; subject to engineers details and specification.

(Planning) Under Pump Sump Island Section

1 : 20



Refer to 'Gilbarco' Pumps & Dispensers Series SK700-2 Site Preparation for further details

(Planning) Pump Cradle & Fuel Riser Setting-Out

1 : 20



It is not proposed to undertake any periodical regime of groundwater testing unless dictated by the local authority. In the event of the leak detection system alarm being activated, the proposed bore holes will allow water samples to be taken for chemical analysis.

The position of the observation well enables water samples to be taken around the underground fuel tanks as required.

(Planning) Monitoring Well Detail

1 : 10

PFS Standard Details

NOTES

All dimensions to be verified on site, and the Architect informed of any discrepancy. All drawings and specifications should be read in conjunction with the Health and Safety Plan; all conflicts should be reported to the Principal Designer.

This drawing is the copyright of C+A Design Limited. ©

DO NOT SCALE FROM THIS DRAWING

Construction staff and operatives must ensure the principle contractor has provided thorough and accurate information on all health and safety aspects relating to the designs identified on this drawing include the review of:

- Designers/contractors risk assessments
- Method statement
- Permit to work
- Construction phase health and safety plan

The designers note that the following health and safety risk relating to this drawing have not been eliminated during the design process:

ref	residual risk

	revision	date	by	chk
C	Control room exterior colour revised, layout updated.	15/05/18	JF	MRJ
B	Site revised to be automated. Jet wash bays and vacuum unit omitted.	04/05/18	JF	MRJ
A	Issue For Planning	05/12/17	JEM	MRJ

CLIENT

ASDA
Save money. Live better.

C+A Design Ltd. 2b - 3b Hathersage Business Park, Heather Lane, Hathersage, S32 1DP
Tel: 01433 652220 Web: www.cad-ltd.co.uk

DRAWING ISSUE

○ Preliminary ○ Costing ○ Construction
● Planning ○ Tender ○ Record

date	scale @ A1	drawn by	checked by
05/12/17	As indicated	JEM	MRJ

ASDA Ferring PFS
Littlehampton Road, Ferring, BN12 6PN

PFS Standard Details

role	originator	volume	levels	type	suitability
A	CA	S0	XX	DR	S4

project number	drawing number	revision
1731FW	500_01	C

M 20 40 60 80 1:1250
1 2 3 1:500
0.5 1 1.5 1:20

173FW-CA-S0-XX-DR-A-500_01-S4-PFSStandardDetails

file reference: C:\REVIT JF\ASDA 2018\Ferring (1)\ferring(173FW-CA-S0-XX-DR-A-PFSMST-XX-XX).rvt