

From: Carol Reynolds
Sent: 18 August 2017 17:17
To: Planning.Responses
Subject: RE: Planning Consultation on FG/108/17/DOC

Environmental Health: Refuse application for discharge of Condition 4 in respect of post validation testing to determine compliance with the requirements of BS8233:2014. Those Acoustic Reports provided by Sound Advice Acoustics Ltd, Ref SA -5031 in respect of Plot 1-4 (1st to 4th July 2017) and SA – 4993 in respect of Plot 37 – 40 (24th to 27th June 2017) clearly demonstrate an unacceptably high incidence of peak noise, defined as 45dBLAFMax, within first floor bedrooms during night time hours. This is despite investigations having taken place predominantly over the week end, when traffic flow might be expected to be less. Please provide detail of those further mitigation measures which will be provided to achieve the required standard. Any further post completion validation testing to be carried out on at least 2 days within that period Monday to Friday.

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 25 July 2017 17:04
To: EH Planning Consultations
Subject: Planning Consultation on FG/108/17/DOC

To: Environmental Health - Anna Appleton

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION FG/108/17/DOC
NO:

Registered: 19-JUL-17
Site Address: 1 Bennett Gardens Ferring BN12 6PN

Description of Works: Application for approval of matters reserved by condition imposed under FG/104/14/PL relating to condition 4 (blocks 1-4

& 37-40) for post validation testing for internal noise assessment.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 8th August 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr J Baeza who can be contacted on telephone number 01903 737765.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
