



**KAZYS NARBUTAS
CONSULTING**

Civil Engineering Consultant

Unit 5B
Tanners Court
Tanners Lane
East Wellow
Romsey
Hampshire
SO51 6DP

1st June 2021

Our Ref: KHN/KNC2108

3 Lime Close,
Reigate.
RH2 8AP

For the attention of Mr. G. Dorrington

Dear Mr. Dorrington,

Re: 14 Sark Gardens, Ferring, West Sussex BN12 5QB
Removal of Sycamore Tree

Further to my recent site visit and our subsequent conversation, I would confirm my recommendation that the sycamore tree sited near to the boundary of the above property and the adjacent property, 15 Sark Gardens, should be removed.

I am of the opinion that the roots from this tree, if not already, will cause damage to the foul drain that runs beneath the canopy of this tree. I suggest the tree is taken down and you undertake an exploratory excavation to establish if any damage has been done to the drain, undertaking remedial work if deemed necessary.

Please do not hesitate to contact me if I can be of further assistance.

Yours sincerely,

K. H. Narbutas BSc., C.Eng., M.I.C.E., M.C.I.H.T.
Kazys Narbutas Consulting