

[illegible]

Equipment Schedule:			Heat Exchangers														
Reference	Floor	Location	No. Off.	Dimensions			Output	Power Supply	Running Current	Weight	Room Temp	F&R Temp	Exchanger Type	Water Flow (kg/s)	Conn. Size	Conn. Type	Manufacturer
				Height (mm)	Width (mm)	Depth (mm)	(kW)	(240V/3-Ø)	(A)	(kg)	(°C)	(°C)					
HEX.01	Grd	CH Warehouse	1	500	500	380	12500	240/1.75-Ø	0.5	20	10	80.00	Water Air Heatsink	0.570	2 1/4"	Comp.	Wintersun
HEX.02	Grd	Warehouse Entrance	1	500	500	380	12500	240/1.75-Ø	0.5	20	10	80.00	Water Air Heatsink	0.540	2 1/4"	Coupling	Wintersun
HEX.03	Grd	Warehouse Entrance	1	500	500	380	12500	240/1.75-Ø	0.5	20	10	80.00	Water Air Heatsink	0.580	2 1/4"	Coupling	Wintersun
HEX.04	Grd	Warehouse Area	1	500	500	380	12500	240/1.75-Ø	0.5	20	10	80.00	Water Air Heatsink	0.580	2 1/4"	Coupling	Wintersun
HEX.05	Grd	Warehouse Area	1	500	500	380	12500	240/1.75-Ø	0.5	20	10	80.00	Water Air Heatsink	0.580	2 1/4"	Coupling	Wintersun
HEX.06	Grd	Warehouse Area	1	500	500	380	12500	240/1.75-Ø	0.5	20	10	80.00	Water Air Heatsink	0.570	2 1/4"	Coupling	Wintersun

DETAIL A
WAREHOUSE WARM AIR HEATER DETAIL

