

Environmental Health Consultation Response

To	Harry Chalk
Date	11-04-2026
Planning Ref	FG/14/26/DOC
Site Description	58 Ferring Street Ferring Worthing West Sussex BN12 5JP
Date of Application	2026-02-27 00:00:00
Category	
Recommendation	No Objection No Objection — with conditions Objection Holding Objection

EH Comments:

I have reviewed the submitted information; however this still does not provide sufficient evidence that the proposed unit will comply with the requirements of condition 3.

The applicant has still not submitted a noise assessment, they have just submitted part of a data sheet for the unit with the octave band data and stated that there should be no reason for the A/C unit to exceed its octave band frequency.


The submitted graph shows the NC curves which is the American standard not the required NR curve as set out in condition 3. The levels in the graph show the unit as operating over the NC45 curve with no assessment of what the level will be at the nearest noise sensitive property. The data graph also shows the levels undertaken in lab conditions not in situ, so does not take into account any reflected sound as would present in the proposed position.

As previously stated, until the noise is properly assessed by a competent person, I must recommend refusal of this application to discharge condition 3.

Conditions Recommended:

PL- Consultation- Environmental Health response

FG/14/26/DOC



Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Our priorities...

 Improving the wellbeing of Arun	 Delivering the right homes in the right places	 Supporting our environment to support us	 Fulfilling Arun's economic potential	 Our core foundations	 
---	--	--	--	---	--

Connect with us: [Facebook](#) | [X](#) | [Instagram](#)

From: chris.white@arun.gov.uk <chris.white@arun.gov.uk>
Sent: 11 April 2026 11:43
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Chris White <Chris.White@arun.gov.uk>
Subject: Planning Response FG-14-26-DOC - 58 Ferring Street, Ferring, Worthing, West Sussex, BN12 5JP

Planning Response FG-14-26-DOC - 58 Ferring Street, Ferring, Worthing, West Sussex, BN12 5JP

Hi Harry,

Please find attached EH planning response for the above application..
Kind Regards

Chris White
Environmental Protection Officer, Environmental Health
Arun District Council

T: 01903 737663
E: chris.white@arun.gov.uk

Council Information:

Environmental Health, Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF

T: 01903 737500 - E: EHPlanningConsultations@arun.gov.uk

<http://www.arun.gov.uk>
NLPG UPRN 100062237016
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

